



State of Louisiana  
Louisiana Department of Health  
Public Health Laboratories  
5604-A Coliseum Boulevard, Room A102  
ALEXANDRIA, LA 71303  
318-487-5282 ext197  
lab.ldh.la.gov



July 26, 2024

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

<b>Public Water System:</b>	LA1115071	<b>Sample ID:</b>	R2401240-001
	VERNON PARISH WATER AND SEWER COMMISSION	<b>Sample type:</b>	Routine
<b>PWS facility:</b>	DS0950	<b>Sample collector:</b>	Randle Holaway
<b>DISTRIBUTION SYSTEM</b>		<b>Collection date:</b>	7/24/2024 3:58:00PM
<b>Sampling location:</b>	TCR-006	<b>Lab submittal date:</b>	7/25/2024 9:41:00AM
<b>323 JEAN CHAPEL EXT</b>			
<b>Collection address:</b>			
<b>Free chlorine (mg/L):</b>	2.48		
<b>Total chlorine (mg/L):</b>			

Component Name	Results	Units	MCL
<b>Coliforms - Presence/Absence</b>			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

<b>Public Water System:</b>	LA1115071	<b>Sample ID:</b>	R2401240-002
	VERNON PARISH WATER AND SEWER COMMISSION	<b>Sample type:</b>	Routine
<b>PWS facility:</b>	DS0950	<b>Sample collector:</b>	Randle Holaway
<b>DISTRIBUTION SYSTEM</b>		<b>Collection date:</b>	7/24/2024 4:05:00PM
<b>Sampling location:</b>	TCR-007	<b>Lab submittal date:</b>	7/25/2024 9:41:00AM
<b>214 COOPER CHURCH RD</b>			
<b>Collection address:</b>			
<b>Free chlorine (mg/L):</b>	1.87		
<b>Total chlorine (mg/L):</b>			

Component Name	Results	Units	MCL
<b>Coliforms - Presence/Absence</b>			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

---

<b>Public Water System:</b>	LA1115071	<b>Sample ID:</b>	R2401240-003
	VERNON PARISH WATER AND SEWER COMMISSION	<b>Sample type:</b>	Routine
<b>PWS facility:</b>	DS0950	<b>Sample collector:</b>	Randle Holaway
<b>DISTRIBUTION SYSTEM</b>		<b>Collection date:</b>	7/24/2024 4:17:00PM
<b>Sampling location:</b>	TCR-008	<b>Lab submittal date:</b>	7/25/2024 9:41:00AM
<b>Collection address:</b>	BLACKMON RD		
<b>Free chlorine (mg/L):</b>	1.53		
<b>Total chlorine (mg/L):</b>			

Component Name	Results	Units	MCL
<b>Coliforms - Presence/Absence</b>			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

---

<b>Public Water System:</b>	LA1115071	<b>Sample ID:</b>	R2401240-004
	VERNON PARISH WATER AND SEWER COMMISSION	<b>Sample type:</b>	Routine
<b>PWS facility:</b>	DS0950	<b>Sample collector:</b>	Randle Holaway
<b>DISTRIBUTION SYSTEM</b>		<b>Collection date:</b>	7/24/2024 4:33:00PM
<b>Sampling location:</b>	TCR-013	<b>Lab submittal date:</b>	7/25/2024 9:41:00AM
<b>Collection address:</b>	MOSS HILL		
<b>Free chlorine (mg/L):</b>	1.77		
<b>Total chlorine (mg/L):</b>			

Component Name	Results	Units	MCL
<b>Coliforms - Presence/Absence</b>			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

---

<b>Public Water System:</b>	LA1115071	<b>Sample ID:</b>	R2401240-005
	VERNON PARISH WATER AND SEWER COMMISSION	<b>Sample type:</b>	Routine
<b>PWS facility:</b>	DS0950	<b>Sample collector:</b>	Randle Holaway
<b>DISTRIBUTION SYSTEM</b>		<b>Collection date:</b>	7/24/2024 3:49:00PM
<b>Sampling location:</b>	TCR-014	<b>Lab submittal date:</b>	7/25/2024 9:41:00AM
<b>Collection address:</b>	ARLINGTON RV PARK		
<b>Free chlorine (mg/L):</b>	2.36		
<b>Total chlorine (mg/L):</b>			

Component Name	Results	Units	MCL
<b>Coliforms - Presence/Absence</b>			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Reviewed by: Samantha Derbonne